

B3 INTERNATIONAL

**BS 8434-2**

**EN 50200 Annex E  
Test Method**

**BS 8434-2 (EN 50200 Annex E test method)**

930°C resistance to fire, water and mechanical shock. The cable is mounted in a U shape on a board with supporting clips, after applying the flame for 5mins a hammer will impact the board on intervals of 5mins, after 60mins the water spray shall start and continue for the remaining 60mins (total test 120mins).

